

Notes - NH0000116

Wednesday, April 21, 2021 9:42 AM

Permit effective date: 08/01/2019

Link to permit: <https://www3.epa.gov/region1/npdes/permits/2019/finalnh0000116permit.pdf>

2020 02 12: Water division issued a [minor permit modification](#) to the permit compliance schedule. The modification allowed 2 extra months for completion of milestone 1 and 2 of the compliance schedule but did not affect the final milestone date.

2021 03 24: NYCOA request EPA a [two-month extension](#) to the Intak Screen Installation (Compliance schedule milestone 3) (Due date: 8/1/2021)

e. Compliance Schedule

The Permittee will need to design and install new equipment to comply with the requirements above. As such, the Permit provides a schedule by which the Permittee shall attain compliance with Part I.C.2.b and I.C.2.c. Specifically, steps for the installation and operation of equipment required to comply with these requirements shall be completed as soon as practicable but no later than the schedule of milestones set forth in the Permit. The Permittee shall notify EPA in writing of compliance or non-compliance with the requirements for each milestone no later than fourteen (14) days following each specified deadline.

- (1) Within six (6) months of the effective date of the Permit, the Permittee shall submit a final design for the intake screens, including the proposed layout and calculation of design through-screen velocity.
- (2) Within twelve (12) months of the effective date of the Permit, the Permittee shall commence the process to obtain all necessary permits and approvals for installation of the intake screens.
- (3) Within twenty-four (24) months of the effective date of the Permit, the Permittee shall complete the installation, test, and startup of the intake screens.

➤ 2021 04 21: EPA response to extension request



NYCOA
letter to E...